

Gas Quality Industry Standards and Methodologies

The Gross Heating Value of gas received shall be determined from read-outs of continuously operating measuring instruments.

The method shall consist of one or more of the following:

- (i) calorimeter
- (ii) gas chromatograph
- (iii) any other method mutually agreed upon by the parties.

Sempra or its agent shall calibrate and maintain its Gross Heating Value measurement device at intervals as agreed upon by parties.

Instruments for detecting moisture content or sulfur content shall meet industry standards and be maintained in accordance with equipment specifications.